



## CRITICAL DETAIL: GAS WATER HEATER TREATMENT

## ENERGY + HEALTH PROGRAM

1. Measure the temperature at the kitchen faucet. If it is not between 115 and 125 degrees Fahrenheit, it needs to be adjusted.

### ✓ CHECK TEMPERATURE



2. Typically, the thermostat on the heater is labeled low to high. Turn the thermostat to the low setting.

### ✓ SET THERMOSTAT



3. After 30 minutes, measure the temperature at the kitchen faucet. It should be between 115 and 125 degrees Fahrenheit.

### ✓ CHECK TEMPERATURE



4. If temperature is too low, adjust the thermostat. Repeat until desired temperature is reached.

### ✓ ADJUST THERMOSTAT



5. Do not install insulation on the top of the heater, anywhere close to the draft hood or flue. It is recommended not to insulate the sides of the heater.

### ✓ PREVENT FIRE HAZARD

